



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

September 25, 2025

Sydney Somes
Siletz - Oak Flats CWS
Confederated Tribes of Siletz
PO Box 549
Siletz, OR 97380
TEL: (541) 444-8289
FAX:

RE:

Order No.: 2509864

Dear Sydney Somes:

Analytical Laboratory Group received 5 sample(s) on 9/23/2025 for the analyses presented in the following report.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401

CC:
Kurtis Barker
Weston Strickler



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 2509864
Date: 9/25/2025

CLIENT: Siletz - Oak Flats CWS

Project:

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

ALG recommends that Public Water Systems monitor the Oregon OHA website (www.yourwater.oregon.gov) to verify that all expected compliance testing results have been entered.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met and test results meet all requirements of TNI except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

Original

WO#: 2509864
CLIENT: Siletz - Oak Flats CWS
Project:
PWS Number: EPA104121121
Sample Source: DIST-A

Received Date: 9/23/2025 12:12:00 PM
Sampler Name: Tenant
Matrix: Drinking Water
Sample Type: Routine

Lab ID:	Client Sample ID				Collection Date:			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Copper	SM 3111 B	0.556	1.30	0.0500		mg/L	9/24/2025 10:00:00 AM	AS
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/24/2025 12:06:00 PM	AS

Lab ID:	Client Sample ID				Collection Date:			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Copper	SM 3111 B	0.0530	1.30	0.0500		mg/L	9/24/2025 10:00:00 AM	AS
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/24/2025 12:06:00 PM	AS

Lab ID:	Client Sample ID				Collection Date:			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Copper	SM 3111 B	0.0589	1.30	0.0500		mg/L	9/24/2025 10:00:00 AM	AS
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/24/2025 12:06:00 PM	AS

Lab ID:	Client Sample ID				Collection Date:			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Copper	SM 3111 B	ND	1.30	0.0500		mg/L	9/24/2025 10:00:00 AM	AS
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/24/2025 12:06:00 PM	AS

Lab ID:	Client Sample ID				Collection Date:			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Copper	SM 3111 B	ND	1.30	0.0500		mg/L	9/24/2025 10:00:00 AM	AS
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/24/2025 12:06:00 PM	AS

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

**Accreditation Program
 Analytes Report**

WO#: 2509864
 25-Sep-25

Client: Siletz - Oak Flats CWS

Project:

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2509864-001A	930 W Buford Kitchen	Drinking Water	AA Metals by SM 3113 Drinking Water	Lead	A
				AA Metals by SM 3111 Drinking Water	Copper	A
	2509864-002A	152 Umpqua Kitchen	Drinking Water	AA Metals by SM 3113 Drinking Water	Lead	A
				AA Metals by SM 3111 Drinking Water	Copper	A
	2509864-003A	223 Umpqua Kitchen	Drinking Water	AA Metals by SM 3113 Drinking Water	Lead	A
				AA Metals by SM 3111 Drinking Water	Copper	A
	2509864-004A	250 Molalla St Kitchen	Drinking Water	AA Metals by SM 3113 Drinking Water	Lead	A
				AA Metals by SM 3111 Drinking Water	Copper	A
	2509864-005A	157 Molalla St Kitchen	Drinking Water	AA Metals by SM 3113 Drinking Water	Lead	A
				AA Metals by SM 3111 Drinking Water	Copper	A

ORELAP A Accredited

ACCRED

Original #2509864# v1

Definitions:

% REC: Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

% RPD: Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

DF: Dilution factor; the dilution factor applied to the prepared sample.

DUP: Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

ND: Not Detected. The analyte level is below the lowest point the laboratory can test for.

PL: Permit limit; only applicable to wastewater reports.

PQL: Practical Quantitation Level (QL) or Reporting Limit; the limit to which data is compared for reporting.

Qual: Qualifier that applies to the analyte reported

Result: Analyte concentration reported

Definitions:

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.



Delivering more than just test results

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 Phone: 541-485-8404 Fax: 541-484-5995
 Email: alglabs@alglabsinc.com

CHAIN OF CUSTODY PUBLIC WATER SUPPLY LEAD & COPPER

◆ DELIVER WITHIN 10 DAYS OF COLLECTION DATE ◆
 ◆ PLEASE SEE SAMPLING INSTRUCTIONS ◆

System Name: Siletz - Oak Flats CWS	PWS ID: 104121121
Attention: Confederated Tribes of Siletz - Sydney Somes	Source ID: DIST- A
Mailing Address: PO Box 549	Sample Type: Circle <u>Routine</u> or Special
Siletz, OR 97380	Tenant
Phone: 541-444-8289	Collected by: <u>Weston Strickler</u>
Email: sydneys@ctsi.nsn.us	Date & Time Collected: Enter Below
Notes: * Crossed out / corrected by client. MT 9/23/25 * * Spec for Lab USC only. MT 9/23/25	If Sample Type is 'Routine' do you want the lab to send a copy to DHS DWP? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>

* 7
001A
002A
003A
004A
005A

Lab ID	Sample Point	Collection		Bottles	Analysis Requested
		Date	Time		
SOF-01	930 W. Buford Kitchen	9-23-25	7:30 AM	1	Lead & Copper
SOF-02	152 Umpqua Kitchen	9-23-25	5:05 AM	1	Lead & Copper
SOF-04	223 Umpqua Kitchen	9-23-25	7:04 AM	1	Lead & Copper
SOF-05	260 Molalla St. Kitchen	9-23-25	6:38 AM	1	Lead & Copper
SOF-06	157 Molalla St Kitchen	9-23-25	7:01 AM	1	Lead & Copper

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via:		IR Refrigerated <u>IR/A</u>	
<input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH		<u>Weston</u>		Ice	<u>None</u>
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>Weston Strickler</u>	9-23-25	12:12	<u>[Signature]</u>	9/23/25	12:12