



ALG ORELAP ID #OR100012  
361 West 5th Ave  
Eugene, OR 97401  
TEL: (541) 485-8404 FAX: (541) 484-5995  
Website:

September 25, 2025

Sydney Somes  
Siletz, Siletz - CWS  
Confederated Tribes of Siletz  
PO Box 549  
Siletz, OR 97380  
TEL: (541) 444-8289  
FAX: (541) 444-2307

RE: Order No.: 2509863

Dear Sydney Somes:

Analytical Laboratory Group received 4 sample(s) on 9/23/2025 for the analyses presented in the following report.

Kimberly Reever Morghan  
Quality Manager  
361 West 5th Ave  
Eugene, OR 97401

CC:  
Kurtis Barker  
Weston Strickler



ALG ORELAP ID #OR100012  
361 West 5th Ave  
Eugene, OR 97401  
TEL: (541) 485-8404 FAX: (541) 484-5995  
Website:

## Case Narrative

WO#: 2509863  
Date: 9/25/2025

---

**CLIENT:** Siletz, Siletz - CWS

**Project:**

---

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

ALG recommends that Public Water Systems monitor the Oregon OHA website ([www.yourwater.oregon.gov](http://www.yourwater.oregon.gov)) to verify that all expected compliance testing results have been entered.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met and test results meet all requirements of TNI except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

---

Original

**WO#:** 2509863  
**CLIENT:** Siletz, Siletz - CWS  
**Project:**  
**PWS Number:** EPA104101136  
**Sample Source:** DIST-A

**Received Date:** 9/23/2025 12:12:00 PM  
**Sampler Name:** Tenant  
**Matrix:** Drinking Water  
**Sample Type:** Routine

Lab ID:	Client Sample ID					Collection Date:		
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Copper	SM 3111 B	0.125	1.30	0.0500		mg/L	9/24/2025 10:00:00 AM	AS
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/24/2025 12:06:00 PM	AS

Lab ID:	Client Sample ID					Collection Date:		
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Copper	SM 3111 B	0.137	1.30	0.0500		mg/L	9/24/2025 10:00:00 AM	AS
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/24/2025 12:06:00 PM	AS

Lab ID:	Client Sample ID					Collection Date:		
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Copper	SM 3111 B	0.228	1.30	0.0500		mg/L	9/24/2025 10:00:00 AM	AS
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/24/2025 12:06:00 PM	AS

Lab ID:	Client Sample ID					Collection Date:		
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Copper	SM 3111 B	0.136	1.30	0.0500		mg/L	9/24/2025 10:00:00 AM	AS
Lead	SM 3113 B	ND	0.0150	0.00200		mg/L	9/24/2025 12:06:00 PM	AS

**Qualifiers:**

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012  
 361 West 5th Ave  
 Eugene, OR 97401  
 TEL: (541) 485-8404 FAX: (541) 484-5995  
 Website:

**Accreditation Program  
 Analytes Report**

WO#: 2509863  
 25-Sep-25

**Client:** Siletz, Siletz - CWS

**Project:**

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2509863-001A	174 Chetco Ct Kitchen	Drinking Water	AA Metals by SM 3113 Drinking Water	Lead	A
				AA Metals by SM 3111 Drinking Water	Copper	A
	2509863-002A	91 Rogue Rvr Ct Kitchen	Drinking Water	AA Metals by SM 3113 Drinking Water	Lead	A
				AA Metals by SM 3111 Drinking Water	Copper	A
	2509863-003A	34B Takelma Ct Kitchen	Drinking Water	AA Metals by SM 3113 Drinking Water	Lead	A
				AA Metals by SM 3111 Drinking Water	Copper	A
	2509863-004A	45B Takelma Ct Kitchen	Drinking Water	AA Metals by SM 3113 Drinking Water	Lead	A
				AA Metals by SM 3111 Drinking Water	Copper	A

ORELAP A Accredited

ACCRED

Original #2509863# v1

### Definitions:

**% REC:** Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

**% RPD:** Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

**DF:** Dilution factor; the dilution factor applied to the prepared sample.

**DUP:** Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

**LCS:** Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

**LCSD:** The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

**MBLK:** Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

**MS:** Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

**MSD:** The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

**ND:** Not Detected. The analyte level is below the lowest point the laboratory can test for.

**PL:** Permit limit; only applicable to wastewater reports.

**PQL:** Practical Quantitation Level (QL) or Reporting Limit; the limit to which data is compared for reporting.

**Qual:** Qualifier that applies to the analyte reported

**Result:** Analyte concentration reported

**Definitions:**

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

**Qualifiers:**

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.



Delivering more than just test results

361 WEST FIFTH AVENUE  
 EUGENE, OREGON 97401  
 Phone: 541-485-8404 Fax: 541-484-5995  
 Email: [alglabs@alglabsinc.com](mailto:alglabs@alglabsinc.com)

## CHAIN OF CUSTODY

### PUBLIC WATER SUPPLY LEAD & COPPER

◆ DELIVER WITHIN 10 DAYS OF COLLECTION DATE ◆

◆ PLEASE SEE SAMPLING INSTRUCTIONS ◆

<b>System Name:</b>	Siletz, Siletz - CWS (Confederated Tribes of Siletz)	PWS ID: 104101136
<b>Attention:</b>	Confederated Tribes of Siletz - Sydney Somes	Source ID: DIST- A
<b>Mailing Address:</b>	PO Box 549	Sample Type: Circle <u>Routine</u> or <u>Special</u>
	Siletz, OR 97380	
<b>Phone:</b>	541-444-8289	Collected by: <u>Tenant</u>
<b>Email:</b>	sydney@ctsi.nsn.us	Date & Time Collected: <i>Enter Below</i>
<b>Notes:</b>	* Per Weston, 9/23/25 EP * For lab use only ⊕ Sample not relinquished, hand out by Lab 9/23/25 EP SSCWS is wasn't home, will have sample avail on 9-24-25	
	If Sample Type is 'Routine' do you want the lab to send a copy to DHS DWP? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	

9/23/25  
 EP  
 001A  
 002A  
 003A  
 004A  
 005A  
 9/23/25

Lab ID	Sample Point	Collection		Bottles	Analysis Requested
		Date	Time		
SSCWS-02	174 Chaco Ct. Kitchen	9-23-25	7:45 AM	1	Lead & Copper
SSCWS-03	91 Rogue Rvr Ct. Kitchen	9-23-25	7:02 AM	1	Lead & Copper
SSCWS-05	345 Takelma Ct. Kitchen	9-23-25	7:02 AM	1	Lead & Copper
SSCWS-09	45B Takelma Ct. Kitchen	9-23-25	7:30 AM	1	Lead & Copper
SSCWS-15	Will collect 9-24-25			1	<del>Lead &amp; Copper</del>

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via:		IR Refrigerated <u>IR/NA</u>	
<input checked="" type="checkbox"/> <b>NORMAL</b> <input type="checkbox"/> <b>RUSH</b>		<u>Weston</u>		Ice <input checked="" type="checkbox"/> <b>None</b>	
Relinquished by:	Date      Time	Received by:	Date      Time		
Relinquished by:	Date      Time	Received by Laboratory:	Date      Time		
<u>Weston Steuber</u>	<u>9-23-25</u> <u>12:12</u>		<u>9/23/25</u> <u>12:12</u>		